



सत्यमेव जयते

GOVT. OF ASSAM  
OFFICE OF THE DIRECTOR  
FIRE AND EMERGENCY SERVICES, ASSAM  
PANBAZAR, GUWAHATI



Form - G

UBIN : 284/878410/AAAGD4798M/10/2024

UAIN : FNESBNOCI/2024/03059

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Low Hazard**

This NOC is issued to **District Institute of Education and Training Dhemaji** on **04/11/2024** with reference to Compliance Report No. **NIL** dated **19/10/2024**

I here by certify that the building as per description below at **Dag No. 316, 317, 318, 319 Patta No. - Mouza Dhemaji Place Sil Ali Majgaon , DHEMAJI** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	BLOCK 1 - 1200 SQM, BLOCK 2 - 102 SQM	BLOCK 1 - OFFICE, SCIENCE LAB, COMMON ROOM, CLASS ROOM, MULTIPURPOSE HALL, LIBRARY, COMPUTER LAB AND BLOCK 2 - CLASS ROOM

THIS NOC IS VALID UP TO **4/11/2027**

Place of issue : **GUWAHATI**  
Date of issue : **04/11/2024**

**Director/Deputy Director/Supdt. of Police cum F&ESA,  
Fire and Emergency Services, Assam,  
Panbazar, Guwahati.**

(Subject to Conditions mentioned here under)

CONDITIONS :

1. There should not be any change of Trade for which this License has been issued.

2. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
3. The fire fighting equipments should be in serviceable condition at all time
4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The NOC is liable to be cancelled if the premises (for which the NOC is granted) when inspected are not found conforming to the description and condition under which this NOC is granted.

**Director/Deputy Director/Supdt. of Police cum F&ESA,  
Fire and Emergency Services, Assam,  
Panbazar, Guwahati.**

